

STAFF REPORT

June 6, 2002

No. 02PL028 - Preliminary and Final Plat

ITEM 3

GENERAL INFORMATION:

PETITIONER	Renner & Sperlich Engineering Co. for Robert E. Moore
REQUEST	No. 02PL028 - Preliminary and Final Plat
EXISTING LEGAL DESCRIPTION	Lot 15 of Kepp Heights Subdivision #3, located in the SW1/4 of the NW1/4 of Section 11, T1N, R7E, BHM, Rapid City, Pennington County, South Dakota
PROPOSED LEGAL DESCRIPTION	Lots 1 thru 15 of Kepp Heights Subdivision #4, located in the SW1/4 of the NW1/4 of Section 11, T1N, R7E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 14.874
LOCATION	South of Flormann Street and Skyline Drive
EXISTING ZONING	Low Density Residential/Planned Development Designation
SURROUNDING ZONING	
North:	Park Forest District
South:	Park Forest District
East:	Low Density Residential District
West:	Park Forest District
PUBLIC UTILITIES	City sewer and water
DATE OF APPLICATION	03/28/2002
REPORT BY	Vicki L. Fisher

RECOMMENDATION:

Staff recommends that the Preliminary and Final Plat be continued **to the June 20, 2002 Planning Commission meeting** to allow the applicant to submit additional information.

GENERAL COMMENTS:

The applicant has submitted a Preliminary and Final Plat to subdivide the subject property into 15 residential lots. The lots range in size from .381 acres to 2.553 acres. The property is located approximately 150 feet south of the intersection of Skyline Drive and Flormann Street on the south and east side of Skyline Drive. In addition, the plat shows the extension of a 49 foot wide right-of-way to serve as access to the proposed lots.

The applicant has also submitted a Variance to the Subdivision Regulations to waive street

STAFF REPORT

June 6, 2002

No. 02PL028 - Preliminary and Final Plat

ITEM 3

improvements along Skyline Drive and to allow lots twice as long as they are wide. (See associate item #02SV015.)

On January 15, 1996, City Council approved Layout Plat #2281 to subdivide the subject property into 15 lots and to subdivide an adjacent property into three lots. (A subsequent lawsuit resulted in the District Court overturning the Layout Plat approval.) On February 7, 2000, the City approved Rezoning Request #99RZ019 and Planned Development Designation #99PD023 to change the zoning from Park Forest District to Low Density Residential District with a Planned Development Designation.

STAFF REVIEW:

Staff has reviewed the Preliminary and Final Plat and has identified the following considerations:

Slope Stability: The Engineering Division has expressed concern with the slope stability as slumping is visible in this area. The applicant has submitted a preliminary geotechnical evaluation, however, a detailed evaluation must be provided prior to any construction and/or approval of the Preliminary Plat. Along with geotechnical evaluation, detailed grading and topographic data must be submitted to insure that additional slope instability does not occur as part of the proposed development. Staff is recommending that the Preliminary and Final Plat be continued to allow the applicant to submit a detailed geotechnical evaluation along with a detailed grading plan and topographic information as identified.

Staff is also recommending that an Initial and Final Planned Residential Development be submitted and approved prior to Final Plat approval in order to insure that buildable areas exist on each of the proposed lot(s). The Skyline Drive corridor is an important asset to the community. As noted in the previously approved Planned Development Designation for the subject property, the Planned Residential Development will need to be developed carefully so as to preserve the scenic view from Skyline Drive. Structures built too close to the roadway could result in a corridor affect along the roadway and obstruct the scenic views from Skyline Drive. The Planned Residential Development will also need to be developed so that the views to Skyline Drive from the rest of the community are protected. Structure locations and elevations will need to be developed so that the view of the ridgeline of Skyline Drive is not adversely affected to a significant extent.

Drainage Plan: The Engineering Division has also indicated that a revised drainage plan must be submitted for review and approval. In particular, the revised drainage plan must provide road ditch design and calculations. In addition, the revised drainage plan must analyze and design necessary controls for protecting Lots 1 thru 7 from drainage off of Skyline Drive. The Engineering Division has indicated that the revised drainage plan must also address downstream impacts due to the increased flows from the proposed development.

Water: City water is currently located directly south of the subject property. The water line was extended along a portion of Skyline Drive as a part of the infrastructure improvements for The Skyline Pines Subdivision located south of the property. Connection fees and agreements must be executed as a part of the Final Plat approval. The Engineering Division has also indicated that additional utility easement(s) and possible oversized lines

STAFF REPORT

June 6, 2002

No. 02PL028 - Preliminary and Final Plat

ITEM 3

must be incorporated into the water design to provide looping with the southwest water zone. Additional valves and hydrants are also needed as a part of the revised water plan. Staff is recommending that a revised water plan be submitted for review and approval prior to Preliminary Plat approval.

Sewer: The Engineering Division has indicated that topographic information must be submitted along Flormann Street in order to identify the provision for access to manhole(s) along this section of roadway. The Engineering Division has indicated that the applicant's site plan shows the location of manholes along Flormann Street to be located south of the road. As such, a reinforced concrete sidewalk must be constructed along the south side of Flormann Street to provide access to the manholes. The Engineering Division has also indicated that the number of manholes must be reduced. In addition, the lowest floor elevation(s) of the proposed residences must be identified on the plat to insure sewer gravity flow. Staff is recommending that a revised sewer plan be submitted for review and approval prior to Preliminary Plat approval.

Street Improvements: Skyline Drive, a 100 foot wide right-of-way with an approximate 24 foot wide paved surface, is located along the west lot line of the subject property. Currently, curb, gutter, street light conduit, sidewalks and dry sewer and water have not been constructed along this section of Skyline Drive. Skyline Drive is classified as a collector road requiring a minimum pavement width of 32 feet. As previously indicated, the applicant has submitted a Variance to the Subdivision Regulations to waive the requirement to install curb and gutter, water, sewer, street light conduit, sidewalks and the requirement to widen the pavement. Prior to Preliminary Plat approval by the City Council, the road construction plans must be revised to meet the minimum design standards as required by the Street Design Criteria Manual or the Subdivision Regulations Variance must be obtained.

In addition, the plat identifies Sunrise Drive, a proposed 49 foot wide right-of-way with a 24 foot wide paved surface, being extended south from Skyline Drive to serve as access to the proposed lots. The Engineering Division has indicated that pavement design for the proposed road must be submitted incorporating geotechnical evaluation(s). In addition, the Engineering Division has indicated that an overhead electric line is located extending north to south through the subject property. The utility line appears to be in close alignment to Sunrise Drive. The location of the existing utility line must be shown on the construction plans. If the utility line is to be relocated, then the relocated area must also be shown. In addition, the plat must be revised to show existing and proposed utility easement(s) for the overhead electric line.

The plat also identifies the dedication of approximately 300 feet of Flormann Street within a 50 foot wide right-of-way. The proposed street is located 150 feet north of the subject property, extending east from Skyline Drive. The proposed extension will be the final tie connecting Flormann Street right-of-way between Skyline Drive and Mount Rushmore Road. Flormann Street is classified as a collector road on the Major Street Plan requiring a minimum 60 foot wide right-of-way width with a 24 foot wide paved surface. Currently, Flormann Street is constructed with a 24 foot wide paved surface within the proposed 50 foot right-of-way with a sidewalk along the north side of the street and curb, gutter and water. The plat must be revised to provide an additional 10 feet of right-of-way as required

STAFF REPORT

June 6, 2002

No. 02PL028 - Preliminary and Final Plat

ITEM 3

by the Street Design Criteria Manual or a Subdivision Variance must be obtained. The Engineering Division has also indicated that Flormann Street was not constructed per the previously reviewed and approved construction plans. The Engineering Division has indicated that Flormann Street must be revised to comply with the previously approved plans or a Variance to the Subdivision Regulations must be obtained.

The Engineering Division has also indicated that a sight distance evaluation is required for the Flormann Street/Skyline Drive intersection. In addition, the Engineering Division has indicated that speed limit and/or advisory signs must be posted as required. The Engineering Division has also indicated that road improvements may be necessary along the intersection depending upon the site distance evaluation. Staff is recommending that the site distance evaluation be submitted for review and approval prior to Preliminary Plat approval and that the road construction plans be revised accordingly.

Fire Department: The Fire Department has indicated that the proposed fire hydrants must be installed and operational prior to issuance of a building permit and/or any construction on the site using combustible material(s). In addition, all proposed streets must be constructed to meet the minimum standards of the Street Design Criteria Manual to insure fire apparatus access.

Lot Configuration: The Subdivision Regulations state that "for lots in residential districts having a width of not more than one hundred fifty feet, the lot length shall not be greater than twice the lot width". The proposed plat identifies that nine of the lots have a length twice the distance of the width. As previously indicated, the applicant has submitted a Variance to the Subdivision Regulations to allow lots more than twice as long as they are wide. Prior to Final Plat approval, the Variance to the Subdivision Regulations must be obtained or the plat must be revised to comply with the length to width requirement.

Emergency Services Communication Center: The Emergency Services Communication Center has indicated that the proposed road name, Sunrise Drive, must be changed. Currently, several streets in and around Rapid City have the word "Sun" in the road name. Prior to Final Plat approval, an alternate road name must be submitted to the Emergency Services Communication Center for review and approval. In addition, the plat must be revised accordingly.

Staff met with the applicant on May 2, 2002 to discuss the outstanding issues as outlined above. On May 13, 2002, the applicant submitted an Initial and Final Residential Development Plan for the subject property and on May 17, 2002, the applicant submitted cross sections for Sunrise Drive. During the review of the Initial and Final Residential Development Plan, staff identified that structure locations and elevations must be submitted to insure that the view from the ridgeline of Skyline Drive is not adversely affected by the proposed development. To date, the structural location and elevation information has not been submitted for review and approval. As such, staff is recommending that the associated Initial and Final Residential Development Plan be continued to the June 20, 2002 Planning Commission meeting. Staff is also recommending that the Preliminary and Final Plat be continued to the June 20, 2002 Planning Commission meeting to be heard in conjunction with the

STAFF REPORT

June 6, 2002

No. 02PL028 - Preliminary and Final Plat

ITEM 3

Initial and Final Residential Development Plan in order to insure that buildable areas exist on the proposed lots.