STAFF REPORT

November 21, 2002

No. 02VE016 - Vacation of Note on Plat

ITEM 19

GENERAL INFORMATION:

PETITIONER Doug Sperlich for Wyss Associates, Inc.

REQUEST No. 02VE016 - Vacation of Note on Plat

EXISTING

LEGAL DESCRIPTION Lots 1 through 11 of Block 2, Skyview North Subdivision

located in the NE1/4 of the SE1/4 of Section 10, T1N, R7E, BHM, Rapid City, Pennington County, South

Dakota

PARCEL ACREAGE Approximately 11.43 acres

LOCATION In the 2000 block of Harney Drive

EXISTING ZONING Low Density Residential District w/Planned Development

SURROUNDING ZONING

North: Low Density Residential District

South: Park Forest District/Low Density Residential District

w/Planned Development

East: Park Forest District

West: Low Density Residential District w/Planned Development

PUBLIC UTILITIES City sewer and water

DATE OF APPLICATION 10/15/2002

REPORT BY Tom Kurtenbach

RECOMMENDATION:

Staff recommends that the Planning Commission recommend that the City Council approve a "Resolution of Modification of Note on Plat" to read, "Buildings on any lots having driveways exceeding 16% slope shall be equipped with an automated residential sprinkler system subject to approval by the Rapid City Fire Department."

GENERAL COMMENTS:

The applicant is proposing to vacate a note on platted property which is legally described as, Lots 1 through 11 of Block 2, Skyview North Subdivision located in the NE1/4 of the SE1/4 of Section 10, T1N, R7E, BHM, Rapid City, Pennington County, South Dakota. The applicant is requesting to vacate the note on all pages of the original Plat document on which it appears.

STAFF REPORT

November 21, 2002

No. 02VE016 - Vacation of Note on Plat

ITEM 19

The plat note in question reads as follows:

"Buildings on any lots having driveways exceeding 15% slope shall be equipped with an automated residential sprinkler system subject to approval by the Rapid City Fire Department."

STAFF REVIEW:

An application to vacate a plat note was submitted by the applicant on October 15, 2002. The Rapid City Fire Department is opposed to the vacation of plat note. The Uniform Fire Code states that when access roads cannot be installed due to location of property, topography, waterways, non-negotiable grades, or similar conditions, the Fire Chief is authorized to require additional fire protection as specified in Section 1001.9 Special Hazards.

According to the City Street Design Criteria Manual, the maximum driveway grade shall not exceed 16 percent. This criterion, in conjunction with other driveway specifications, provides the proper driveway design to support safe ingress and egress for vehicles, including large fire apparatus.

The Fire Department indicated that it could support a revised note which would take into consideration the aforementioned concerns. Based on the information referenced above, Staff can support the revised note as recommended by the Fire Department.