


04PL190



Preliminary Plat of
 LOT 1 of BLOCK 1,
 and LOTS 1, 2, & 3 of BLOCK 2,
 MENARD SUBDIVISION
 UTILITIES - POTABLE WATER

Connect to existing 12" main
 On S side of E Anomosa

Water requirements include City tasking to provide a 12" main from the 12" main in East Anomosa along Creek Drive to eventually form a loop with the 12" main to the south. Service size to each lot is to be determined, but will likely be 6" to provide for required sprinkler systems for commercial structures. Standard City fire hydrants will be installed as shown, at approximately 250-300 spacing, alternating on the sides of Creek Drive. Additional hydrants may be required on the individual lots. All installation of water system shall comply with current City requirements and code as of the date of installation.

Total 5 hydrants in 530'


Street curb & sidewalks omitted for clarity.

RECEIVED

DEC 10 2004

Rapid City Growth
 Management Department

Prepared by N. Barton, 1 DEC 04



PROJECT NO.: WL-5020-06C
 PROJECT NO.: DW-R01-153
 FILE NAME: EastGate6APCD.dwg-itr4
 DATE: 1 DEC 2004

12/13