



EXTERIOR FINISH COLORS		
	FIELD COLORS	ACCENT COLORS
BRICK	EARTH TONE GRAYS	
EIFS	LIGHT GRAYS	DARK GRAYS
ROOF SHINGLES	MEDIUM GRAYS	
DOOR/WINDOW FRAMES	LIGHT TO MEDIUM GRAYS	
SIGNS	SEE SIGN DRAWINGS	SEE SIGN DRAWINGS

- BUILDING ASSEMBLIES**
- (R1) ROOF ASSEMBLY-1 HOUR RATED (UL P522)**
 - COMPOSITE OR ASPHALT SHINGLES, 40 YEAR WARRANTY, UL CLASS A, B OR C ROOFING SYSTEM.
 - FELT PAPER, 15 LBS ON THE FIELD AND 30 LBS WINTERGUARD AT THE EDGES WITH METAL FLASHING.
 - 15/32" NOMIAL C-D GRADE OSB OR PLYWOOD SHEATHING.
 - MANUFACTURED ROOF TRUSSES AT 24" O.C.
 - R38 MINIMUM INSULATION.
 - RESILIENT CHANNELS, NOM. 1/2" DEEP BY 2-3/8" WIDE AT THE BASE AND 1-3/8" WIDE AT THE FACE AT 24" O.C.
 - ONE LAYER OF 5/8" X' GYPSUM BOARD
 - SUSPENDED CEILING SYSTEM (CASINO ONLY)
 - OVERHANGS AS FOLLOWS.
 - 2X FASCIA WITH METAL WRAP
 - METAL VENTED SOFFIT PANELS ON THE NORTH, EAST AND SOUTH OVERHANG, 3" CONTINUOUS METAL VENT ON THE WEST OVERHANG.
 - METAL GUTTERS AND DOWNSPOUTS.
 - (W1) EXTERIOR WALL ASSEMBLY-1 HOUR RATED (UL U335)**
 - EIFS SYSTEM WITH 1-1/2" RIGD FOAM INSULATION SHEATHING.
 - BRICK VENEER WANES COAT AS SHOWN ON THE ELEVATION DRAWINGS WITH WEEP HOLES, FLASHINGS, MORTAR AND TIES PER INDUSTRY STANDARDS AND LOCAL BUILDING CODES.
 - BUILDING PAPER RATED FOR EIFS AND BRICK VENEER.
 - 5/8" X' DENSDECK FIREGUARD SHEATHING.
 - 2X6 STUDS AT 16" O.C
 - MIN. R19 INSULATION
 - ONE LAYER OF 5/8" X' GYPSUM BOARD SHEATHING.
 - (W2) INTERIOR DEMISING WALL ASSEMBLY-1 HOUR RATED (UL U327)**
 - FROM TOP OF FLOOR TO UNDERSIDE OF ROOF SHEATHING.
 - ONE LAYER OF 5/8" X' GYPSUM BOARD SHEATHING
 - RESILIENT CHANNELS AT 24" O.C PERPENDICULAR TO STUDS.
 - 2X6 STUDS AT 16" O.C
 - MINIMUM OF 3-1/2" BATT INSULATION.
 - ONE LAYER OF 5/8" X' GYPSUM BOARD SHEATHING
 - (W3) INTERIOR TENANT WALL ASSEMBLY-NON RATED**
 - FROM TOP OF FLOOR TO 2" MIN ABOVE SUSPENDED CEILING
 - ONE LAYER OF 5/8" X' GYPSUM BOARD SHEATHING
 - 2X4 STUDS AT 16" O.C.
 - ONE LAYER OF 5/8" X' GYPSUM BOARD SHEATHING
 - (F1) INTERIOR CONCRETE SLAB**
 - REINFORCED 4" THICK CONCRETE SLAB,
 - #4 BARS AT 24" O.C. EACH WAY
 - 4" COMPACTED GRAVEL
 - UNDISTURBED SOIL OR STRUCTURAL FILL.
 - (F2) EXTERIOR CONCRETE SLABS AND SIDEWALKS**
 - REINFORCED 4" THICK CONCRETE SLAB,
 - #4 BARS AT 24" O.C. EACH WAY
 - THICKEN THE OUTSIDE EDGE OF FRONT SIDEWALK.
 - 4" COMPACTED GRAVEL
 - UNDISTURBED SOIL OR STRUCTURAL FILL.

BUILDING SECTION
SCALE: 1/4" = 1'-0"

- (FN1) EXTERIOR CONCRETE FOUNDATION BELOW INTERIOR SLAB (NORTH AND SOUTH FOUNDATION WALLS).**
 - REINFORCED 8" THICK CONCRETE WALL (AT EIFS SYSTEM)
 - #5 HORIZONTAL BARS TOP, BOTTOM AND MIDDLE OF WALL.
 - #5 VERTICAL DOWELS (42" VERT BY 9" HOOK) @ 48" O.C EMBEDDED IN FOOTING
 - 42" MINIMUM DEPTH BELOW GRADE
 - 2" THICK RIGD INSULATION ON OUTSIDE FACE OF WALL.
 - CONTINUOUS CONCRETE FOOT (24" WIDE BY 12" HIGH)
 - (3) THREE #5 HORIZONTAL BARS CONTINUOUS.
 - UNDISTURBED SOIL OR STRUCTURAL FILL.
- (FN2) EXTERIOR CONCRETE FOUNDATION BELOW INTERIOR SLAB (EAST FOUNDATION WALL)**
 - REINFORCED 12" THICK CONCRETE WALL (AT BRICK VENEER)
 - #5 HORIZONTAL BARS TOP, BOTTOM AND MIDDLE OF WALL
 - #5 VERTICAL DOWELS (42" VERT BY 9" HOOK) @ 48" O.C EMBEDDED IN FOOTING.
 - 42" MINIMUM DEPTH BELOW GRADE.
 - 2" THICK RIGD INSULATION ON OUTSIDE FACE OF WALL.
 - CONTINUOUS CONCRETE FOOT (24" WIDE BY 12" HIGH)
 - (3) THREE #5 HORIZONTAL BARS CONTINUOUS.
 - UNDISTURBED SOIL OR STRUCTURAL FILL.
- (FN3) EXTERIOR CONCRETE FOUNDATION ABOVE INTERIOR SLAB WITH LESS THAN 4 FEET OF RETAINING AND RISING 6 FEET ABOVE INTERIOR SLAB ON GRADE (WEST FOUNDATION WALL)**
 - REINFORCED 8" THICK CONCRETE WALL
 - #5 HORIZONTAL BARS TOP, BOTTOM AND 48" O.C. BETWEEN.
 - #5 VERTICAL BARS AT 48" O.C
 - 42" MINIMUM DEPTH BELOW GRADE.
 - 2X4 FURRING ON INSIDE FACE OF WALL
 - R13 MINIMUM INSULATION
 - ONE LAYER OF 5/8" X' GYPSUM BOARD.
 - CONTINUOUS CONCRETE FOOT (30" WIDE BY 12" HIGH)
 - (3) THREE #5 HORIZONTAL BARS CONTINUOUS.
 - #5 VERTICAL DOWELS (36" VERT BY 9" HOOK) @ 48" O.C. EMBEDDED IN FOOTING ALIGNING WITH WALL VERTICAL BARS
 - UNDISTURBED SOL OR STRUCTURAL FILL.
- (FN4) EXTERIOR CONCRETE FOUNDATION ABOVE INTERIOR SLAB WITH LESS THAN 4 FEET OF RETAINING AND RISING 6 FEET ABOVE INTERIOR SLAB ON GRADE (WEST FOUNDATION WALL)**
 - REINFORCED 8" THICK CONCRETE WALL
 - #5 HORIZONTAL BARS TOP, BOTTOM AND 48" O.C. BETWEEN.
 - #5 VERTICAL BARS AT 48" O.C
 - 42" MINIMUM DEPTH BELOW GRADE.
 - 2X4 FURRING ON INSIDE FACE OF WALL
 - R13 MINIMUM INSULATION
 - ONE LAYER OF 5/8" X' GYPSUM BOARD.
 - CONTINUOUS CONCRETE FOOT (30" WIDE BY 12" HIGH)
 - (3) THREE #5 HORIZONTAL BARS CONTINUOUS.
 - #5 VERTICAL DOWELS (36" VERT BY 9" HOOK) @ 48" O.C. EMBEDDED IN FOOTING ALIGNING WITH WALL VERTICAL BARS
 - UNDISTURBED SOL OR STRUCTURAL FILL.

KENNEDY DESIGN GROUP INC
 4555 ENCHANTED PINES DRIVE
 RAPID CITY, SD 57701
 PHONE: 605.342.5314
 FAX: 605.342.5314

CLIENT:
 REEL WYNNING LLC
 4941 ENCHANTED PINES DRIVE
 RAPID CITY, SD 57701
 605.716.1800

PROJECT:
 NEW COMMERCIAL WALL
 703 & 705 INDIANA STREET
 RAPID CITY, SD 57701

BUILDING SECTION

PROJECT NO: 527
 FILE NO: 527-2
 DRAWN BY: RKK
 CHECK BY: RKK
 DATE: 12.09.05
 REVISION #1: 0.0.0
 REVISION #2: 0.0.0

A4

Drawing Number