

RECEIVED

**REQUEST FOR EXCEPTION TO
RAPID CITY DESIGN STANDARD AND CRITERIA** NOV 28 2006

PROJECT Park Meadows Phase 2 Lot 16 Block 2 Replat

Rapid City Growth
Management Department

DATE: 11-27-06 SUBMITTED BY: Park Hill Development, Inc.

PIN #: 3807279009 & 3807279010 909 St. Joseph Street #3, RC, SD 57701

LEGAL DESCRIPTION: Lots 16A and 16B of Block 2, Park Meadows Subdivision,

Located in the SE 1/4 NE 1/4 Section 7, T1N, R8E, B.H.M

Rapid City, Pennington County, South Dakota

EXCEPTION REQUESTED: SECTION 7.51 & 8.3.J.2 STANDARD/CRITERIA **Standard**

DESCRIPTION OF REQUEST: Request to allow existing fire hydrant to be reset approximately 34' north of current location in lieu of salvaging existing fire hydrant and installing new. See attached plan

JUSTIFICATION: Existing hydrant was installed spring 2003 and is in good working condition. Propose to have existing hydrant inspected by City of Rapid City Personnel prior to reset to ensure existing hydrant is in satisfactory condition

SUPPORTING DOCUMENTATION: Yes No

STAFF COMMENTS: see attached

STAFF RECOMMENDATION: deny - see attached

BY: [Signature]

DATE: 11/29/06

AUTHORIZATION: APPROVED

DENIED

Robert J. Dominick, DSCC
GROWTH MANAGEMENT DIRECTOR

11/29/06
DATE

[Signature]
PUBLIC WORKS DIRECTOR

Deny

11-30-06
DATE

FILE #: 06EX081
ASSOCIATED FILE#: 06PL098