

## SECTION 100

### PORTLAND CEMENT

#### 100.1 ~~DESCRIPTION~~ ~~GENERAL REQUIREMENTS~~

##### A. General

Portland cement shall be used as called for herein.

##### B. Related Work

Section 40 Portland Cement Concrete Pavement  
 Section 55 Concrete Masonry  
 Section 56 Concrete ~~f~~For Incidental Construction (Class M)  
 Section 60 Concrete Curb And Gutter  
 Section 61 Concrete Sidewalk And Handicap Ramps  
 Section 62 Drop Inlets  
 Section 67 Fabric Formed Concrete Mat

#### 100.2 MATERIALS (Not specified)

#### 100.32 CONSTRUCTION ~~SPECIFIC~~ REQUIREMENTS

Portland Cement shall conform to the requirements of AASHTO M 85 for the type specified. Type II cement shall not have more than 0.60 percent of Alkalies ( $\text{Na}_2\text{O} + 0.658\text{K}_2\text{O}$ ).

Unless otherwise permitted by the Engineer, the product of only one mill of any one brand and type of Portland cement shall be used on the project.

#### ~~100.3~~100.4 METHOD OF MEASUREMENT & 100.54 BASIS OF PAYMENT

Portland cement shall be incidental to and shall be paid as a part of the individual bid item. There will be no separate measurement and payment for Portland cement.

**END OF SECTION**