

POTENTIAL WATER SERVICE AREA FOR RESERVOIR WITH OVERFLOW=3784±
 EXTENDS UP THE PIEDMONT VALLEY AREA TO TILFORD


PROPOSED 750,000 GAL. WATER STORAGE TANK
 OVERFLOW EL = 3784±

PROPOSED 12" WATER MAIN


PROPOSED 10" WATER MAIN

PROPOSED 10" WATER MAIN

PROPOSED BOOSTER STATION



F M G, Inc.
 3700 Sturgis Road
 Rapid City, SD 57702-0317
 (605) 342-4105 FAX (605) 342-4222
 www.fmgengineering.com



File Number:	8981.04
Location:	XXX XXX
Surveyed By:	XXX
Date:	XXX
Designed By:	ADF
Drawn By:	JRK
Checked By:	ADF

GOOD SAMARITAN
 WATER SYSTEM STUDY
 RAPID CITY, SOUTH DAKOTA

Revision / Date

Sheet Name:

RECOMMENDED FACILITIES

Figure Number:

2.3

AUGUST 2007