

STAFF REPORT
January 10, 2008

No. 07SV062 - Variance to the Subdivision Regulations to waive the requirement to install sidewalk, water and sewer along North Maple Avenue as per Chapter 16.16 of the Rapid City Municipal Code

ITEM 48

GENERAL INFORMATION:

APPLICANT	Thomas E. Lien
AGENT	Janelle Finck for Fisk Land Surveying & Consulting Engineers
PROPERTY OWNER	Gikling and Meier, LLC
REQUEST	No. 07SV062 - Variance to the Subdivision Regulations to waive the requirement to install sidewalk, water and sewer along North Maple Avenue as per Chapter 16.16 of the Rapid City Municipal Code
EXISTING LEGAL DESCRIPTION	A portion of the unplatted balance of the N1/2 NW1/4, Section 30, T2N, R8E, BHM, Rapid City, Pennington County, South Dakota
PROPOSED LEGAL DESCRIPTION	Lots 2 thru 4 of LJS Subdivision, located in the NW1/4, Section 30, T2N, R8E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 34.09 acres
LOCATION	2310 North Maple Avenue
EXISTING ZONING	General Commercial District
SURROUNDING ZONING	
North:	General Commercial District
South:	Shopping Center District 2
East:	General Commercial District
West:	General Commercial District
PUBLIC UTILITIES	City sewer and water
DATE OF APPLICATION	10/26/2007
REVIEWED BY	Vicki L. Fisher / Mary Bosworth

RECOMMENDATION:

Staff recommends that the Variance to the Subdivision Regulations to waive the requirement

STAFF REPORT
January 10, 2008

No. 07SV062 - Variance to the Subdivision Regulations to waive the requirement to install sidewalk, water and sewer along North Maple Avenue as per Chapter 16.16 of the Rapid City Municipal Code

ITEM 48

to install sidewalk, water and sewer along North Maple Avenue be **continued to the January 24, 2008 Planning Commission meeting at the applicant's request.**

GENERAL COMMENTS:

(Update, January 3, 2008. All revised and/or added text is shown in bold print.) This item was continued at the November 21, 2007 Planning Commission meeting at the applicant's request. On January 2, 2008, the applicant submitted a written request that this item be continued to the January 24, 2008 Planning Commission meeting. As such, staff is recommending that the Variance to the Subdivision Regulations be continued as requested.

The applicant has submitted a Variance to the Subdivision Regulations to waive the requirement to install sidewalk, water and sewer along North Maple Avenue as it abuts the property. In addition, the applicant has submitted a Preliminary Plat (#07PL147) to subdivide the property into three lots.

On January 15, 2007, the City Council approved a Layout Plat to create three lots, which included a portion of this property.

The property is located in the southeast corner of the intersection of Mall Drive and North Maple Avenue. Currently, a 10,000 square foot commercial building is located on proposed Lot 3. The balance of the property is void of any structural development.

STAFF REVIEW:

Staff has reviewed the Variance to the Subdivision Regulations and has noted the following considerations:

North Maple Avenue: North Maple Avenue is located along the south and west lot lines of the subject property. The street is classified as a commercial street requiring that it be located in a minimum 59 foot wide right-of-way and constructed with a minimum 26 foot wide paved surface, curb, gutter, sidewalk, street light conduit, water and sewer. Currently, North Maple Avenue is located in a 100 foot wide right-of-way and constructed with an approximate 40 foot wide paved surface, curb, gutter and street light conduit. In addition, water and sewer mains have been installed along a portion of North Maple Avenue. In particular, an eight inch water main is located along the north-south portion of North Maple Avenue abutting proposed Lot 2. An eight inch water main has also been extended from an existing 12 inch water main located in East Mall Drive to serve the commercial building on proposed Lot 3. The applicant is proposing to extend the water main from proposed Lot 3 to serve proposed Lot 4 creating a long dead end water main service. A public water main does not exist along the east-west leg of North Maple Avenue and the north-south leg of North Maple Avenue as it abuts proposed Lot 4. In lieu of providing a water main connection along this portion of North Maple Avenue, staff is recommending that the applicant extend the water main from Lot 3 to the intersection of Disk Drive and North Maple Avenue to provide a looped system. In addition, staff is recommending that the applicant sign a waiver of right to protest any future assessments for the water main along the balance of North Maple Avenue as it abuts

STAFF REPORT
January 10, 2008

No. 07SV062 - Variance to the Subdivision Regulations to waive the requirement to install sidewalk, water and sewer along North Maple Avenue as per Chapter 16.16 of the Rapid City Municipal Code

ITEM 48

the property.

A sewer main is currently located in North Maple Avenue with the exception of approximately 165 feet of the north-south leg as it abuts proposed Lot 2. Extending sewer to the north lot line of proposed Lot 2 will provide a sewer service to this area of the property and to the unplatted balance located directly north of proposed Lot 2. As such, staff is recommending that the Variance to the Subdivision Regulations to waive sewer along this portion of North Maple Avenue be denied.

Currently, sidewalk does not exist along this portion of North Maple Avenue. However, this is a commercial area and it is anticipated that as this area continues to develop with commercial use(s), additional pedestrian traffic will be generated between the use(s). It has also been the position of the City Council that a sidewalk be provided as a part of the development of a site to insure pedestrian safety within our community. In order to provide a safe place for pedestrians to walk, staff is recommending that a sidewalk be provided along one side of the street.

Notification Requirement: As of this writing, the receipts from the certified mailings have been returned.