



CITY OF RAPID CITY
RAPID CITY, SOUTH DAKOTA 57701-5035

Growth Management Department
300 Sixth Street

Mary Bosworth, Engineering Project Manager
Growth Management Department
city web: www.rcgov.org

Phone: 605-394-4157
Fax: 605-394-6636
e-mail: mary.bosworth@rcgov.org

February 11, 2008

Fisk Land Surveying & Consulting Engineers, Inc.
P.O. Box 8154
Rapid City, SD 57709

Re: Auto Zone, Building Permit
Pin #2131327010
Request for Exception to Maximum Driveway Opening Width

The Request for Exception to Section 8.2.1.B of the City of Rapid City Street Design Criteria Manual, to increase the maximum driveway opening width to thirty-six feet (36') is denied. Section 8.2.1.B states commercial driveway openings shall be no more than twenty-eight feet (28') in width, exclusive of the taper. The requested driveway width will not provide safe and orderly vehicle access to and from this property.

The denial of this exception request may be appealed to the City Council by requesting it be placed on the next Public Works Committee agenda. Please contact the Growth Management Department if you desire to appeal. The City Council has final approval of exception requests.

Sincerely,

Mary Bosworth, P.E.
Engineering Project Manager

Cc: Files



EQUAL OPPORTUNITY EMPLOYER