

AMERICAN ENGINEERING TESTING, INC.

Percolation Test Information
 Dewald Property
 Nameless Cave Road
 Rapid City, South Dakota
 AET # 18-02720

	Test Hole #1		Test Hole #2		Test Hole #3	
Inch 1	12	Minutes	15	Minutes	16	Minutes
Inch 2	18	Minutes	12	Minutes	14	Minutes
Inch 3	15	Minutes	13	Minutes	16	Minutes
Inch 4	20	Minutes	15	Minutes	20	Minutes
Inch 5	25	Minutes	20	Minutes	30	Minutes
Inch 6	30	Minutes	15	Minutes	24	Minutes
Inch 7		Minutes	30	Minutes		Minutes
Inch 8		Minutes		Minutes		Minutes
Inch 9		Minutes		Minutes		Minutes
Inch 10		Minutes		Minutes		Minutes
Inch 11		Minutes		Minutes		Minutes
Inch 12		Minutes		Minutes		Minutes
		Minutes		Minutes		Minutes
Averages	20	Minutes/Inch	17	Minutes/Inch	20	Minutes/Inch

Average of all three holes 19 minutes/Inch

Person completing the percolation testing Michael Brown *Michael Brown*
 Printed Name Signature

8-foot Soil Profile Information

	Soil Type
1 foot	Sandy Clay
2 foot	
3 foot	
4 foot	
5 foot	
6 foot	
7 foot	
8 foot	

Remarks: **Boring B-4**
 0 - .4 feet - Sandy Clay with organics brown
 .4 - 11.5 feet - Sandy Clay brown to red, some gravel and sand lenses

Person completing the soil profile information Robert Temme P.E. *Robert Temme*
 Printed Name Signature

RC FORM 990 3/05

RECEIVED

APR 25 2008

Rapid City Growth
 Management Department