



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

JOE FOSS BUILDING
PMB 2020
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.denr.sd.gov

October 05, 2010

Karl Merbach
City of Rapid City Regional Recycling and Landfill
300 6th St.
Rapid City, SD 57701

WARNING LETTER

RE: Effluent Violation Summary for Permit SD0027685

Dear Mr. Merbach:

The South Dakota Department of Environment and Natural Resources has recently conducted a file review of the wastewater treatment facility for the City of Rapid City Regional Recycling and Landfill. The purpose of this letter is to provide you with a summary of violations that were reported by your personnel on Discharge Monitoring Reports (DMRs) for the above specified period.

The following is a list of reported violations from submitted DMRs, not covered by another letter:

<u>DMR</u>	<u>Mth/Year</u>	<u>Parameter</u>	<u>Limit</u>	<u>Reported Value</u>
001A	3 / 2010	Nitrogen, ammonia total (as N)	1 mg/L 30DA AVG	2.7 mg/L
001A	3 / 2010	Nitrogen, ammonia total (as N)	1.8 mg/L DAILY MX	2.7 mg/L
001A	5 / 2010	Solids, total suspended	53 mg/L DAILY MX	58 mg/L
001A	5 / 2010	Solids, total suspended	30 mg/L 30DA AVG	41 mg/L

Every effort must be made to comply with your permit limits. Continuing to have violations can lead to an enforcement action which can include fines up to \$10,000 per day per violation. If you feel you have received this letter in error, please contact me at (605) 773-4731.

Sincerely,

Tim Flor
Environmental Project Scientist/Enforcement
Surface Water Quality Program

C: SWQ File - Pierre Office