

Partial List of ADA Issues – Civic Center

- 1) Foremost is Lack of ADA Compliance
 - a) ADA accessible seating
 - 1) 70 – 75 ADA accessible seats + 70 - 75 companion seats distributed throughout the facility in all seating options / sight lines. Additional participant ADA accessible locations on benches, boxes or team locations
 - b) Aisle width issues in certain parts of bowl and a lack of railing in all aisles
 - c) No ADA compliant elevators
 - 1) Need Elevators to each type of seating location and option
 - 2) Need enough elevators to handle the 5,000 – 7,000 patrons in the Bowls seating (3-5)
 - d) No TRUE ADA restrooms on main floor
 - 1) We have created our own ADA restroom stalls that do not meet all the codes for turn radias' and widths
 - 2) Lacking the sheer numbers of restrooms needed for the number of patrons we have, especially female restrooms
 - e) No ADA accessibility to concession for patrons or merchandise stands
 - 1) No ADA accessibility for employee's or workers
 - f) No ADA ingress/egress doors to the Barnett Arena with required access rail
 - g) No ADA accessible locker rooms, shower stalls or lockers
 - h) No ADA accessibility to the backstage, star dressing rooms
 - i) No Elevators for access to the Star Dressing Rooms
 - j) Roof does not comply to modern snow load requirements
 - 1) Cannot handle larger concerts as the roof trussing load requirements and location of
 - 2) Current grid system cannot handle events using the full arena (Walking with Dinosaurs)
 - k) Even after two electrical upgrades – lacking show power and electrical amperage needed for larger shows
 - l) Insufficient lighting & blackout capability for sporting events and larger family shows
 - m) Insufficient sound coverage for larger national speakers and presentors
 - m) Technology that predates the 1st IBM PC computer, such as 1,000 pair of Cat 1 telecommunication wires that cannot be used for any modern phones, internet or electronic communications
 - n) Lack of Voice evac system for fire alarm system / not tied into remainder of building