



RECEIVED  
MAY 31 2013  
MAYOR'S OFFICE

DEPARTMENT of ENVIRONMENT  
and NATURAL RESOURCES  
JOE FOSS BUILDING  
PMB 2020  
523 EAST CAPITOL  
PIERRE, SOUTH DAKOTA 57501-3182  
www.denr.sd.gov

May 22, 2013

Sam Kooiker  
City of Rapid City  
300 6th St.  
Rapid City, SD 57701-2724

## WARNING LETTER

RE: Effluent Violation Summary for Permit SD0023574

Dear Mayor Kooiker:

The South Dakota Department of Environment and Natural Resources has recently conducted a file review of the Surface Water Discharge permit for the City of Rapid City.

The purpose of this letter is to provide you with a summary of violations that were reported by your personnel on Discharge Monitoring Reports (DMRs) for the specified period listed below.

The following is a list of reported violations from submitted DMRs, not covered by another letter:

<u>DMR</u>	<u>Mth/Year</u>	<u>Parameter</u>	<u>Limit</u>	<u>Reported Value</u>
001A	5 / 2012	Coliform, fecal general	400 #/100mL DAILY MX	1520 #/100mL
001A	7 / 2012	Coliform, fecal general	400 #/100mL DAILY MX	590 #/100mL
001A	8 / 2012	Coliform, fecal general	400 #/100mL DAILY MX	865 #/100mL
001A	8 / 2012	Oxygen, dissolved (DO)	6.5 mg/L DAILY MN	5.89 mg/L

**Every effort must be made to comply with your permit limits. Continuing to have violations can lead to an enforcement action which can include fines up to \$10,000 per day per violation.** If you feel you have received this letter in error, please contact me at (605) 773-4731.

Sincerely,

Tim Flor  
Environmental Scientist III/Enforcement  
Surface Water Quality Program

C: SWQ/Enforcement File