


- NOTES:
1. SLOPE OR BENCH PER OSHA REQUIREMENTS AND SAFE EXCAVATION PRACTICES.
  2. FORCE MAIN MATERIAL: HDPE 4710 DR9. CONSTRUCT USING 1000-FT ROLLS TO MINIMIZE THE NUMBER OF FUSED JOINTS.
  3. WATER MAIN MATERIAL: PER CITY STANDARD SPECIFICATIONS.
  4. FOUNDATION MATERIAL, PIPE BEDDING MATERIAL AND BACKFILL MATERIAL FOR THE WATER MAIN PORTION OF THE TRENCH SHALL BE SAME AS SHOWN FOR THE FORCE MAIN PORTION OF THE TRENCH (NOT SHOWN FOR CLARITY).



**CONCEPTUAL**  
**NOT FOR CONSTRUCTION**

**RENNER & ASSOCIATES, LLC.**  
616 BRYAN ST., RAPID CITY, SD 57701  
PHONE: 605/721-7310 FAX: 605/721-7313  
CITY HALL, 1002

Prepared By: \_\_\_\_\_

Scale: \_\_\_\_\_

Designed By: MKK	Drawn By: MKK
Design Date: DEC. 2013	Print Date: 12-17-2013
Surveyed By: N/A	Survey Date: N/A

Revisions: \_\_\_\_\_

**CALLE BAJA UTILITIES**  
RAPID CITY, SOUTH DAKOTA

Location: \_\_\_\_\_

Prepared For: **TOM AND MARY HELLAND**  
4200 CALLE BAJA  
RAPID CITY, SD 57702  
PH. 605-400-9285

Internal Job No: **#2523.01**

Sheet Title: **PROPOSED CONFIGURATION**

Sheet: **2 of 2**