

# **CITY OF RAPID CITY**

## RAPID CITY, SOUTH DAKOTA 57701-2724

### OFFICE OF THE CITY ATTORNEY

300 Sixth Street

Carla R. Cushman, Assistant City Attorney

City web: <a href="https://www.rcgov.org">www.rcgov.org</a>

Phone: 605-394-4140

Fax: 605-394-6633 e-mail: carla.cushman@rcgov.org

#### **MEMORANDUM**

TO: Legal and Finance Committee

FROM: Carla Cushman, Assistant City Attorney

DATE: April 29, 2015

RE: Standard provisions in the International Residential Code concerning shifting,

compressible, and expansive soils.

The following provisions are part of the International Residential Code (2012 version) and would be adopted by the City if Ordinance 6009 passes in its current form. Amendments to these versions are proposed in Ordinance 6050.

#### R401.4 Soil tests.

Where quantifiable data created by accepted soil science methodologies indicate expansive, compressible, shifting or other questionable soil characteristics are likely to be present, the building official shall determine whether to require a soil test to determine the soil's characteristics at a particular location. This test shall be done by an approved agency using an approved method.

#### **R401.4.1** Geotechnical evaluation.

In lieu of a complete geotechnical evaluation, the load-bearing values in Table R401.4.1 shall be assumed.

# TABLE R401.4.1 PRESUMPTIVE LOAD-BEARING VALUES OF FOUNDATION MATERIALS<sup>a</sup>

CLASS OF MATERIAL	LOAD-BEARING PRESSURE (pounds per square foot)
Crystalline bedrock	12,000
Sedimentary and foliated rock	4,000
Sandy gravel and/or gravel (GW and GP)	3,000
Sand, silty sand, clayey sand, silty gravel and clayey gravel (SW, SP, SM, SC, GM and GC)	2,000
Clay, sandy clay, silty clay, clayey silt, silt and sandy silt (CL, ML, MH and CH)	1,500 <sup>b</sup>

For SI: 1 pound per square foot = 0.0479 kPa.

- a. When soil tests are required by Section R401.4, the allowable bearing capacities of the soil shall be part of the recommendations.
- b. Where the building official determines that in-place soils with an allowable bearing capacity of less than 1,500 psf are likely to be present at the site, the allowable bearing capacity shall be determined by a soils investigation.

#### **R401.4.2** Compressible or shifting soil.

Instead of a complete geotechnical evaluation, when top or subsoils are compressible or shifting, they shall be removed to a depth and width sufficient to assure stable moisture content in each active zone and shall not be used as fill or stabilized within each active zone by chemical, dewatering or presaturation.

#### **R403.1.8.1** Expansive soils classifications.

Soils meeting all four of the following provisions shall be considered expansive, except that tests to show compliance with Items 1, 2 and 3 shall not be required if the test prescribed in Item 4 is conducted:

- 1. Plasticity Index (PI) of 15 or greater, determined in accordance with ASTM D 4318.
- 2. More than 10 percent of the soil particles pass a No. 200 sieve (75 μm), determined in accordance with ASTM D 422.
- 3. More than 10 percent of the soil particles are less than 5 micrometers in size, determined in accordance with ASTM D 422.
- 4. Expansion Index greater than 20, determined in accordance with ASTM D 4829.