



February 5, 2008

Rapid City Journal
507 Main Street
Rapid City, SD 57701

RE: Area A – Refer to BHR Drawing #MA-2.4.4-1.

Dear Mr. Red Leaf:

The two old signage sanctions will be removed. As you can see the seams at the coping joints have been previously repaired. This is why we have give the option to take the membrane up and over the top as depicted in detail #MA- 2.1.48 – alternate #1.



February 5, 2008

Rapid City Journal
507 Main Street
Rapid City, SD 57701

RE: Area A – Refer to BHR Drawing #MA-1.8.1.

Dear Mr. Red Leaf:

Gutter and downspouts are in good condition to reuse, we will clean out the debris.