

KA"= IFY

Bulman Karen

From: Sent: jesseallstar@rushmore.com Friday, May 18, 2012 2:17 PM

To:

Bulman Karen

Subject:

RE:

Karen,

Yes, there will only be rails on top and bottom with spindles in between. The spindles will be 2"x2" redwood.

Jesse

>

```
On Fri 05/18/12 1:26 PM , Bulman Karen <u>Karen.Bulman@rcgov.org</u> sent:
> Jesse,
>
>
>
> These are good pictures. Looking at the pictures and the drawings, I
> am assuming that the only rails will be the top and bottom and that
> spindles will be used instead. If you have a design for the spindles,
> that would be helpful. Are they just going to be 1" square or something else?
> Thanks.
> Karen
>
  ----Original Message----
> From: jesseallstar@rushmore.com [jes
> seallstar@rushmore.coml
> Sent: Friday, May 18, 2012 11:19 AM
> To: Bulman Karen
>
> Subject:
>
>
> Hi Karen,
>
>
> Here are some pictures of the existing deck at 1208 West Boulevard.
> Only a small portion on the left side of the house is visible frome the street.
> Please let me know if there is any thing else I will need.
>
```