

STAFF REPORT

November 7, 2002

---

**No. 02PL083 - Preliminary and Final Plat**

**ITEM 8**

---

GENERAL INFORMATION:

PETITIONER	Dream Design International, Inc.
REQUEST	No. 02PL083 - Preliminary and Final Plat
EXISTING LEGAL DESCRIPTION	The unplatted portion of the NW1/4 of the SW1/4, Section 3, T1N, R8E, BHM, Rapid City, Pennington County, South Dakota
PROPOSED LEGAL DESCRIPTION	Lots 1 thru 4, Block 1, Lots 1 thru 9, Block 2, and Outlot A and Dedicated Streets, Neff Subdivision II, Section 3, T1N, R8E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 3.99 acres
LOCATION	The cul-de-sacs at the west end Sweetbriar Street and Avenue A
EXISTING ZONING	Suburban Residential District (County)
SURROUNDING ZONING	
North:	Suburban Residential District (County)
South:	Suburban Residential District (County)
East:	Suburban Residential District (County)
West:	Low Density Residential District w/Planned Residential Development (City)
PUBLIC UTILITIES	Rapid Valley Sanitary Sewer and Water
DATE OF APPLICATION	07/26/2002
REPORT BY	Tom Kurtenbach

RECOMMENDATION:

**The applicant has requested that the Preliminary and Final Plat be continued to the December 5, 2002 Planning Commission meeting to allow the applicant time to submit additional required information.**

GENERAL COMMENTS: (Updates to the staff report are shown in bold.) **This item was continued from the October 24, 2002 Planning Commission meeting.** This Preliminary and Final Plat request has been submitted to subdivide a 3.99 acre tract into 13 single family residential lots and one outlot. This request is the companion item to an associated Rezoning request (file #02RZ042), an Annexation request (file #02AN007) and a Subdivision Regulations Variance request (file #02SV036). The property is located at the

## STAFF REPORT

November 7, 2002

---

**No. 02PL083 - Preliminary and Final Plat**

**ITEM 8**

---

west terminus of Sweetbriar Street and Avenue A. The proposed lots range in size from 0.18 acres to 0.29 acres. The applicant is proposing to rezone the property from No Use District to Low Density Residential Zoning District and the applicant has requested a Variance to the Subdivision Regulations to allow for residential lots that are twice as long as they wide.

STAFF REVIEW: Staff has reviewed the Preliminary and Final Plat request and noted the following considerations:

Drainage Plans: The Engineering Division and the Pennington County Drainage Engineer have both noted that the drainage design plans submitted with this Preliminary and Final Plat request assume that drainage improvements identified in the Race Track Draw Detention Pond Project have been constructed. To date, these drainage improvements have not been completed. Because of the potential impacts on downstream property owners, staff is recommending that prior to Preliminary Plat approval by the Planning Commission that all the drainage improvements included in the Race Track Draw Detention Cell Project must be constructed and functional. **The drainage improvements included in the Race Track Draw Detention Cell Project are currently under construction.**

The Engineering Division has reviewed the applicant's drainage plans and noted other revisions to the applicant's drainage plan that must be addressed prior to Preliminary Plat approval. Staff has returned the Engineering Division comments and redlined design plans to the applicant for review and revision. **As of October 28, 2002, the applicant has not submitted revised storm water design plans.**

Water and Sanitary Sewer: The Rapid City Engineering Division has noted on the design plans submitted with this request that the applicant must work with the Rapid Valley Sanitary District to ensure that the design plans are in compliance with all the requirements of Rapid Valley Sanitary District. In addition, the Rapid Valley Sanitary District has requested that the applicant schedule a pre-construction meeting prior to initiation of the construction of the subdivision improvements.

Street Lights: Section 16.16 of the Rapid City Municipal Code requires that the subdivider provide street light conduit for the installation of streetlights. Staff is requesting that the applicant revise the design plans to show the location of proposed street lights and the provision of the required street light conduit. In addition, the Engineering Division has requested that the applicant include the location of electrical transformers and service locations on the revised design plans. **The Engineering Division had also requested an Electrical Distribution plan to allow the evaluation of potential conflict(s) of those improvements with drainage facilities or other subdivision development. As of October 28, 2002, the applicant has not submitted the requested electrical plans.**

Geotechnical Data: The Engineering Division has noted that geotechnical engineering data must be submitted for review to verify the applicant's pavement design plans. **The applicant has submitted the requested pavement design and geotechnical engineering data which is currently under review by Engineering staff for approval.**

STAFF REPORT

November 7, 2002

---

No. 02PL083 - Preliminary and Final Plat

ITEM 8

---

Master Plan: As mentioned previously, the applicant has submitted a request to annex the subject property as well as property to the north and west into the City of Rapid City's corporate limits. Staff is requesting that the applicant submit a master plan identifying the anticipated development of the area being annexed that is not included in this Preliminary and Final Plat request. **As of October 28, 2002, the applicant has not submitted the requested master plan.**

Pennington County Register of Deeds: The Pennington County Register of Deeds has noted that the subdivision name "Neff Subdivision II" has previously been used within Pennington County. The applicant will need to select a different subdivision name for review and approval by the Pennington County Register of Deeds. **As of October 28, 2002, the applicant has not submitted a different subdivision name for review and approval.**

City/County Maintenance Agreement: This Preliminary and Final Plat proposes to extend the existing Sweetbriar Street and Avenue A to the west approximately 400 feet. Currently, the existing Sweetbriar Street and Avenue A are outside of the Rapid City limits and are maintained by the Pennington County Highway Department. The applicant has requested that the proposed subdivision be annexed into the Rapid City limits and as such the extension of Sweetbriar Street and Avenue A will be maintained by the City of Rapid City. The City of Rapid City and Pennington County will need to draft an agreement identifying what services, such as snow removal, will be provided by which agency.