

STAFF REPORT

June 5, 2003

No. 03PL045 - Preliminary and Final Plat

ITEM 9

GENERAL INFORMATION:

PETITIONER	Michael Hanson for Kent Hagg Esq. for Burnell A. Lutz
REQUEST	No. 03PL045 - Preliminary and Final Plat
EXISTING LEGAL DESCRIPTION	Lot K1-E of Lot K-1 in Marshall Heights Tract, Section 25, T2N, R7E, BHM, Rapid City, Pennington County, South Dakota
PROPOSED LEGAL DESCRIPTION	Lots A and B of Lot K1-E of Lot K-1 in Marshall Heights Tract, Section 25, T2N, R7E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately .510 acres
LOCATION	1903 North Maple Avenue
EXISTING ZONING	General Commercial District
SURROUNDING ZONING	
North:	Shopping Center II
South:	Medium Density Residential District
East:	General Commercial District
West:	General Commercial District
PUBLIC UTILITIES	City Sewer and Water
DATE OF APPLICATION	04/11/2003
REPORT BY	Tom Kurtenbach

RECOMMENDATION: Staff recommends that the Preliminary and Final Plat be continued to the **June 26**, 2003 Planning Commission Meeting to allow the applicant to submit additional information.

GENERAL COMMENTS: **(Updates to the staff report are shown in bold.) This item was continued from the May 22, 2003 Planning Commission meeting to allow the applicant to submit additional information. The required information has not been submitted by the applicant for review by staff. As such, staff is recommending that this plat request be continued to the June 26, 2003 Planning Commission meeting.**

The applicant is proposing to split an approximate 0.5 acre parcel into two lots. The subject property is located north of Knollwood Drive and west of Maple Avenue. A convenience store with fuel sales currently occupies the subject property. The applicant is proposing to

STAFF REPORT

June 5, 2003

No. 03PL045 - Preliminary and Final Plat

ITEM 9

split the lot to allow on sale liquor sales in close proximity to fuel sales. Currently, the Rapid City Municipal Code does not allow on sale liquor sales within 100 feet of fuel sales on the same lot.

STAFF REVIEW: Staff has reviewed the Preliminary Plat and has noted the following considerations:

Drainage: Based on information submitted by the applicant, the Engineering staff has recommended that a Major Drainage easement be identified on the north end of proposed Lot A. Engineering staff recommends that the Preliminary and Final Plat be continued to allow the applicant to revise the plat identifying a major drainage easement on the plat.

Sewer and Water Services: Information submitted by the applicant does not identify water and sewer service lines to proposed Lots A and B. This information is necessary to verify whether each lot will have dedicated service lines, or whether a common service line is planned for the development. The applicant has requested a Special Exception to allow one main to service both lots. If a "private main" is planned to serve the subject property, Engineering staff recommends that plans prepared by a Registered Professional Engineer be submitted for review and approval. Generally, shared service lines have proven problematic, and staff does not support their use. Additionally, the applicant shall submit information identifying the location, size and construction material for the water and sewer service lines to each proposed lot. Staff recommends that the proposed plat be continued to allow the applicant to submit the required water and sewer system information.

Access: Currently access to the subject property is provided from Knollwood Drive and Maple Avenue. The access point along Knollwood Drive is currently less than 50 feet from Maple Avenue. The applicant has requested a Special Exception to the Street Design Criteria Manual allowing the Knollwood access point to remain as it is currently constructed. Currently, a second access point to the subject property exists along Maple Avenue. Engineering staff has recommended that a joint access location be identified to provide future access from Maple Avenue to proposed Lots A and B. Staff recommends that the proposed plat be continued to allow the applicant to submit the required access information.

Subdivision Name: The Pennington County Register of Deeds staff recommended that the applicant submit a new subdivision name for review and approval. Staff recommends that prior to Final Plat approval by the City Council, a new subdivision name shall be submitted for review and approval.

Knollwood Drive and Maple Avenue Rights of Way: The plat submitted by the applicant does not identify the Knollwood Drive and Maple Avenue right of way widths. Staff recommends that prior to Final Plat approval by the City Council, the plat shall be revised to identify the right of way widths for these streets.

Staff recommends that the Preliminary and Final Plat be continued to the **June 26, 2003** Planning Commission Meeting to allow the applicant to submit additional information as outlined above.