

STAFF REPORT

September 25, 2003

No. 03PL089 - Preliminary and Final Plat

ITEM 29

GENERAL INFORMATION:

PETITIONER	Dream Design International, Inc. for Hank Craig
REQUEST	No. 03PL089 - Preliminary and Final Plat
EXISTING LEGAL DESCRIPTION	A portion of Lot B of the N1/2 of Government Lot 4, located in the SW1/4 of the SW1/4 of Section 18, T1N, R8E, BHM, Rapid City, Pennington County, South Dakota
PROPOSED LEGAL DESCRIPTION	Lots 1, 2 and 3 of Craig Estates, located in the SW1/4 of the SW1/4 of Section 18, T1N, R8E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 0.569 acres
LOCATION	Along the 4200 Block of Parkview Drive
EXISTING ZONING	Low Density Residential District
SURROUNDING ZONING	
North:	General Agriculture District
South:	General Agriculture District
East:	Low Density Residential District/General Agriculture District
West:	Public District
PUBLIC UTILITIES	City sewer and water
DATE OF APPLICATION	08/29/2003
REPORT BY	Vicki L. Fisher

RECOMMENDATION:

Staff recommends that the Preliminary and Final Plat be continued to the October 23, 2003 Planning Commission meeting to allow the applicant to submit additional information.

GENERAL COMMENTS:

The applicant has submitted a Preliminary and Final Plat to subdivide the subject property into three lots leaving a 14.601 acre non-transferable balance. In addition, the applicant has submitted a Variance to the Subdivision Regulations to waive the requirement to construct curb, gutter, sidewalk, street light conduit, sewer, water and pavement along a well access easement. (See companion item 03SV033.)

STAFF REPORT

September 25, 2003

No. 03PL089 - Preliminary and Final Plat

ITEM 29

On August 20, 2001 the City Council denied without prejudice Layout, Preliminary and Final Plat #00PL100 to subdivide the subject property into two lots.

The property is located approximately 1,400 feet south of the Minnesota Street/Parkview Drive intersection on the east side of Parkview Drive. Currently, a single family residence and a pole barn are located on the 14.601 acre non-transferable balance.

STAFF REVIEW:

Staff reviewed the Preliminary and Final Plat and has noted the following considerations:

Access Easement: The plat document identifies a 60 foot wide well access easement located along the south lot line of the subject property. Prior to Preliminary Plat approval by the City Council, construction plans for the access easement must be submitted for review and approval or a Variance to the Subdivision Regulations must be obtained. In addition, the plat document must be revised to show a non-access easement along the south lot line of proposed Lot 3 as it abuts the access easement.

Parkview Drive: Currently, Parkview Drive is being constructed as part of an assessment project by the City. However, the construction plans do not provide for the construction of sidewalks and street light conduit. As such, prior to Preliminary Plat approval by the City Council, construction plans providing a four foot wide property line sidewalk and street light conduit must be submitted for review and approval or a Variance to the Subdivision Regulations must be obtained. In addition, the plat document must be revised to show a non-access easement along Parkview Drive except for approved approach locations.

Drainage Plan: The storm sewer improvements currently being constructed along Parkview Drive do not account for the increase in density created by developing the subject property. Additional inlets and storm water capacity may be necessary based on the proposed site grading and increase in density. Staff is recommending that a revised drainage plan be submitted for review and approval addressing the drainage concerns as outlined above.

Master Plan: As previously indicated, the proposed plat will leave an approximate 14.601 acre non-transferable balance. As such, a Master Plan must be submitted for review and approval identifying future lot configurations as well as road and utility extensions through the site. In addition, a structural site plan must be submitted for review and approval identifying the existing structures and on-site water and/or wastewater system(s). The Master Plan must also identify access to the non-transferable balance from Parkview Drive and/or Elm Street. It appears problematic to construct a street within the current location of the well access easement extending off Parkview Drive as this will create double street frontages on lots currently being platted south of the subject property. As such, staff would support vacating a portion of the sixty foot wide access easement creating a flagpole lot to the existing single family residence. This would allow the applicant to either plat a fourth lot along Parkview Drive or increase the size of the three proposed lots. Access to the non-transferable balance would then be from Elm Avenue. Due to the significance of the

STAFF REPORT

September 25, 2003

No. 03PL089 - Preliminary and Final Plat

ITEM 29

proposed road and utility extensions through the non-transferable balance, staff is recommending that the Preliminary and Final Plat be continued to the October 23, 2003 Planning Commission meeting to allow the applicant to submit a Master Plan as outline above.