

STAFF REPORT

December 4, 2003

---

**No. 03SR044 - 11-6-19 SDCL Review to allow construction of an additional golf cart barn and parking** **ITEM 6**

---

GENERAL INFORMATION:

PETITIONER	City of Rapid City
REQUEST	<b>No. 03SR044 - 11-6-19 SDCL Review to allow construction of an additional golf cart barn and parking</b>
EXISTING LEGAL DESCRIPTION	Tract 4 and the north 27 feet of vacated Flormann Street (also in Section 10, T1N, R7E) Rapid City Greenway Tract, Section 9, T1N, R7E, BHM, Rapid City, Pennington County, South Dakota
LOCATION	Meadowbrook Golf Course, 3625 Jackson Boulevard
EXISTING ZONING	Park Forest District
SURROUNDING ZONING	
North:	Park Forest District
South:	Medium Density Residential District
East:	Medium Density Residential District
West:	Flood Hazard District
PUBLIC UTILITIES	City sewer and water
DATE OF APPLICATION	10/10/2003
REPORT BY	Karen Bulman

RECOMMENDATION: Staff recommends that the 11-6-19 SDCL Review to allow construction of an additional golf cart barn and parking be continued to the **December 18, 2003** Planning Commission meeting to allow the applicant to submit further information and a revised site plan.

GENERAL COMMENTS: **This staff report has been revised as of November 21, 2003. All revised and/or added text is shown in bold print.** The applicant is proposing to add one golf cart storage barn adjacent to the cart barn located at 3625 Arrowhead Drive. The proposed barn will be 50 feet by 138 feet and 8 feet in height with a peaked roof. It will have metal siding, sky lights and an asphalt floor. The color will be white to match the existing cart barn. The City Council gave approval for the project to proceed on October 6, 2003.

The property is located in the Park Forest Zoning District. Property located north of the subject property is zoned Park Forest District. Flood Hazard District is located on property to the west of the subject property. Property located south and east of the subject property

## STAFF REPORT

December 4, 2003

---

### No. 03SR044 - 11-6-19 SDCL Review to allow construction of an additional golf cart barn and parking ITEM 6

---

is zoned Medium Density Residential District.

South Dakota Codified Law 11-6-19 states that "...whenever any such municipal council has adopted a comprehensive plan, then no street, park or other public way, ground, place, space, no public building or structure, no public utility, whether publicly or privately owned, if covered by the comprehensive plan or any adopted part thereof, shall be constructed or authorized in the municipality or within its subdivision jurisdiction until and unless the location and extent thereof shall have been submitted to and approved by the Planning Commission". The proposed use is a public structure and located within the area covered by the Rapid City Comprehensive Plan requiring that the proposed expansion be reviewed and approved by the Rapid City Planning Commission as a part of an 11-6-19 SDCL Review.

STAFF REVIEW: Staff has reviewed the proposed 11-6-19 SDCL Review as it relates to the applicable provisions of the Rapid City Municipal Code and has noted the following issue:

Fire Department: The Fire Department is recommending that the building be sprinklered due to the nature of the electrical charging system set-up for the batteries for the golf carts and the recent past fire history of the charging systems. The Fire Department is also requiring on-site fire hydrants and posting of the building address on the structure. The address numbers shall be a minimum of 12 inches in size, with a contrast in color to the background color and shall be plainly visible from the street. The access roads must also be designed and maintained to support the imposed loads of fire apparatus.

Engineering/Public Works Department: Upon submittal of a building permit, the applicant shall provide plans for grading, paving, drainage, and any utility improvements including water lines for fire hydrants and sprinkler systems. The cart barn will be located on land that is currently sloped. As such, prior to Planning Commission approval, the Public Works Division is requesting a revised site design with a grading plan.

Urban Department: The proposed cart barn will accommodate 80 golf carts. The size of the building will require that a minimum of two additional parking stalls be provided. All parking stalls shall be striped and curb stops placed on those stalls located adjacent to the proposed cart barn. The parking lot and access to the lot shall be paved. Cart access to the golf course is not clearly identified. There is a potential circulation conflict between carts and pedestrians. A revised site plan is required to show the access points for the golf carts and pedestrian circulation. Landscaping requirements state that a minimum of 50% of the required landscaping must be located within a parking lot or within 20 feet of a parking lot. A minimum of one landscaping island must be provided in the parking lot. The applicant is requesting that the requirement that a minimum of 50% landscaping be provided in the parking lot be waived due to the large amount of landscaping required for the golf course size and the location of all the landscaping already established on the golf course.

Staff is requesting that the 11-6-19 Review be continued to the **December 18, 2003** Planning Commission meeting to allow the applicant to provide additional information and a

STAFF REPORT

December 4, 2003

---

**No. 03SR044 - 11-6-19 SDCL Review to allow construction of an additional golf cart barn and parking**      **ITEM 6**

---

revised site plan.

Staff notes that 11-6-19 South Dakota Codified Law Reviews do not require direct notification of neighboring property owners. In addition, South Dakota Codified Law does not require that 11-6-19 South Dakota Codified Law reviews be advertised in a local newspaper.