

RECEIVED

APR 05 2006

Rapid City Growth Management Department

06SR028

9' West of Existing Hydrant  
0+00 F&I  
6" Tapping Tee  
and Valve Assembly  
5" to 6" Increase  
Begin 2" PVC C-900  
Water Main

Wildwood Drive

Lot 23-B  
Book 15 Page 135

Lot 20  
Book 9 Page 2

0+05.5 - 0+12  
Asphalt Patch per  
City Detail

2+47.5 F&I  
18" x 8" 90' Bend  
2" Bend

4+34.0 F&I  
6" x 6" Tee and  
Valve & Hydrant Assembly  
and 6" x 8" 90' Valve  
Bend

4+44.0 F&I  
Cap @ End of Map

Lot A  
Book 12 Page 162

Lot B  
Book 12 Page 162

Overhead Transmission Lines  
Note Proximity of Water  
Main Bend Point

Balance of Lot 1

3+35 - 3+90  
Remove and Replace  
Existing Gravel  
Drive as Necessary.

Lot 1

