

Farmers Supply, LLC
2401 S. Hwy 79
Rapid City, SD 57701
605-342-0800

JULY 28 06

REF.
BRENT PUSHING. WELL TEST

DEAR SIR;

I HAVE COMPLETED THE FLOW TEST AND THE RESEARCH ON YOUR SHARED WELL ON TOP OF THE HILL. THIS WELL IS PRESENTLY PRODUCING 10 GAL PER MIN, WHICH IS 600 GAL PER HR OR 14000 GAL, PER 24 HR PERIOD. THIS TEST WAS CONDUCTED WITH THE PRESENT PUMP AT FULL CAPACITY AND AT 10 PSI ON GAUGE. WE HAVE NO WAY OF TELLING IF THIS DRAWS THE WATER DOWN VERY FAR FROM THE STATIC LEVEL.

THE SCHOOL OF MINES AND THE US GEOLOGICAL SURVEY BOTH WERE CONTACTED AND DID NOT HAVE ANY RECORD OF THIS PARTICULAR WELL.

I HAVE ALSO CONTACTED THE CITY OF RAPID CITY AND THE STATE DENR OFFICE IN RAPID CITY AND THEY DO NOT HAVE A RECOMMENDATION OF THE GAL PER DAY REQUIRED FOR EACH HOUSEHOLD. THE ONLY RECOMMENDATION I COULD GET IS 150 GAL PER DAY PER PERSON, AND I HAVE ALSO BEEN TOLD THAT FIGURE IS PROBABLY GOING TO BE RAISED. ALSO THIS IS A MINIMUM RECOMMENDATION FOR PERSONAL USE ONLY.

THE PRESENT SPECIFICATIONS OF THIS WELL ARE LISTED BELOW

INFORMATION AS OF NOV 2005

BOTTOM	625'
STATIC WATER LEVEL	360'
OLD PUMP SETTING	483'
NEW PUMP SETTING	567'

I HOPE THIS INFORMATION IS SUFFICIENT FOR YOUR PRESENT PURPOSES.

YOURS TRULY,



E. C. BALCOM