



**NOTE**

1. ALL FENCE WOOD SHALL BE #2 CEDAR
2. ALL HARDWARE SHALL BE GALVANIZED OR NON-CORROSSIVE
3. FACEBOARDS SHALL BE SCREWED (1 3/4" SCREWS) TO CROSSBOARDS, ALL CROSSBOARDS WILL BE SCREWED TO POSTS (1 3/4" SCREWS) ALL CONCRETE FOOTINGS SHALL BE 61 BAG MIX 2500 PSI CONCRETE

**FENCE CLEAR SEALANT NOTES**

1. CONTRACTOR TO USE OLYMPIC WOOD PROTECTOR CLEAR WATER-PROOFING SEALER OR CONSTRUCTION MANAGER APPROVED EQUAL OLYMPIC PRODUCTS MAY BE PURCHASED AT LOCAL HARDWARE STORE
2. CONTRACTOR SHALL APPLY (2) TWO COATS OF ABOVE REFERENCE SEALER TO FENCE

**ASSOCIATED ENGINEERING, INC**  
 2730 N. MAIN STREET  
 OMAHA, NE 68102  
 PH: (402) 426-1111  
 FAX: (402) 426-1111  
 AE NO. PROJECT #24

REGISTERED PROFESSIONAL ENGINEER  
 REG. NO. 2498  
 TOM MEDHI

PROJECT MANAGER  
**i wireless**

APP. CAN. / OWNER  
**SWS, LLC**

DESIGNED BY: JOHN B. ...  
 DATE: ...

SITE NAME  
**ST. ISAAC**

WIRELESS SITE NUMBER  
**SD0144**

SUBMITTALS  
 DATE: ...  
 BY: ...

DRAWING TITLE  
**FENCE DETAILS**

DRAWING NUMBER  
**C-5**

JOB NUMBER  
**XXXX**