

**FLASHING TO BE INSTALLED:**

1. AT WALL AND ROOF INTERSECTIONS
2. WHEREVER THERE'S A CHANGE IN ROOF SLOPE OR DIRECTION.
3. AROUND ROOF OPENINGS

**ICE PROTECTION:**

2 LAYERS OF UNDERLAYMENT CEMENTED TOGETHER AND EXTENDED FROM EAVE'S EDGE TO POINT AT LEAST 24" INSIDE THE EXTERIOR WALL LINE OF BUILDING.

**ROOF DRAINAGE:**

COLLECT AND DISCHARGE ALL ROOF DRAINAGE TO THE GROUND SURFACE AT LEAST 5 FEET FROM FOUNDATION WALLS OR TO AN APPROVED DRAINAGE SYSTEM.

**ROOF DESIGN:**

VERIFY HEEL HGTs. ON TRUSSES. ALL HEEL HGTs. MAY NOT BE THE SAME.

RECEIVED

FEB 24 2012

RAPID CITY COMMUNITY PLANNING  
& DEVELOPMENT SERVICES