

STAFF REPORT
March 22, 2012

No. 12PD010 - Initial and Final Commercial Development Plan

ITEM 9

GENERAL INFORMATION:

APPLICANT	Nathan Herbst
AGENT	Hermanson Egge Engineering, Inc.
PROPERTY OWNER	River City Properties, LLC
REQUEST	No. 12PD010 - Initial and Final Commercial Development Plan
EXISTING LEGAL DESCRIPTION	Lot 3 less the south 30 feet located in the NW1/4 SW1/4 of Section 5, T1N, R8E, BHM, Rapid City, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 7.38 acres
LOCATION	1316 Cambell Street
EXISTING ZONING	General Commercial District (Planned Development Designation)
SURROUNDING ZONING	
North:	General Commercial District
South:	General Commercial District
East:	Flood Hazard District
West:	Flood Hazard District
PUBLIC UTILITIES	Rapid City
DATE OF APPLICATION	2/24/2012
REVIEWED BY	Fletcher Lacock / Brandon Quiett

RECOMMENDATION:

Staff recommends that the Initial and Final Commercial Development Plan be continued to the April 5, 2012 Planning Commission meeting.

GENERAL COMMENTS:

The applicant has submitted an Initial and Final Commercial Development Plan to construct a Kia car dealership on the property. The Billion KIA car dealership was located on the property to the north before a fire razed the building in the past year. The applicant proposes to demolish the existing structure on the property to the north and to build the new dealership on the above legally described property.

On August 2, 1999, the City Council denied without prejudice a Layout Plat (File #99PL070) to subdivide the above legally described property.

STAFF REPORT
March 22, 2012

No. 12PD010 - Initial and Final Commercial Development Plan

ITEM 9

On April 1, 2002, the City Council approved a Rezoning request from Flood Hazard District to General Commercial District (File #02RZ007) for a portion of the above legally described property.

On May 9, 2002, Planning Commission approved a Planned Development Designation (File #02PD013) for the above legally described property.

The property is located on the east side of Cambell Street southeast of the intersection of Cambell Street and East Saint James Street. Currently, the property is void of any structural development but was used as parking for Billion Kia.

STAFF REVIEW:

Staff met with the applicant to review the outstanding issues relative to the Initial and Final Commercial Development Plan request. At the meeting, it was determined that this request must be continued to the April 5, 2012 Planning Commission meeting to allow the applicant to address the floodplain issues located on the property. As such, staff recommends that this item be continued to the April 5, 2012 Planning Commission with the applicant's concurrence.

In addition to the floodplain concerns associated with the property, staff has noted the following considerations:

Engineering: Engineering staff has reviewed the plans submitted by the applicant and has identified issues that must be addressed prior to Planning Commission approval. In particular, the applicant must submit a sanitary sewer design for the modifications to the sewer main along Cambell Street for review and approval, the applicant must submit a stormwater report signed and stamped by a professional engineer which illustrates how the requirements for quality and quantity control of stormwater will be achieved, the applicant must submit a grading plan which reflects the stormwater facility grading and details and a revised site plan addressing redline comments must be submitted for review and approval.

The applicant is proposing curbside sidewalk along Cambell Street. The applicant must obtain an exception to allow curbside sidewalk or revise the plans to comply with Section 7.5 of the Street Design Criteria Manual. In addition, the site plan shows a driveway on Cambell Street that does not align with the opposite driveway. The applicant must obtain an exception to allow the driveway approach on Cambell Street that does not align with the opposite driveway or revise the plans to comply with Section 8.2.4 of the Street Design Criteria Manual.

The applicant has not submitted an erosion and sediment control plan with this application. Prior to issuance of a building permit, an erosion and sediment control plan and notes must be submitted for review and approval.

Landscaping: The applicant has submitted a landscaping plan showing a total of 158,910 landscaping points. A minimum of 158,243 landscaping points must be provided. All provisions of Section 17.50.300, the Landscaping Regulations of the Rapid City Municipal Code must be continually met. All landscaping must be continually maintained in a live

STAFF REPORT
March 22, 2012

No. 12PD010 - Initial and Final Commercial Development Plan

ITEM 9

vegetative state and replaced as necessary.

Parking: Prior to Planning Commission approval, a revised parking plan shall be submitted showing five handicap parking spaces, with one parking space being “van accessible.” A minimum of 127 parking spaces shall be provided. In addition, five of the parking spaces shall be handicap accessible. One of the handicap spaces shall be “van accessible.” All provisions of the Off-Street Parking Ordinance shall be continually met.

Signage: The applicant has submitted a sign package that includes directional signage, wall mounted signs and a pylon sign. All signage must continually conform to Chapter 15.28 of the Rapid City Municipal Code. No electronic signs are being approved as a part of this Initial and Final Planned Commercial Development. All signage not in conformance with Chapter 15.28 of the Rapid City Municipal Code or any electronic reader board signs will require the review and approval of a Major Amendment to the Planned Commercial Development. Lighting for the signs must be designed to preclude shining on the adjacent properties and/or street(s). A sign permit must also be obtained for each individual sign.

Lighting: The applicant is proposing outdoor lighting and has submitted a lighting package with a photometric plan. All outdoor lighting must be reflected within the property boundaries so as to not shine onto adjoining properties and rights-of-way and to not be a hazard to the passing motorist or constitute a nuisance of any kind.

Building Permit: A building permit must be obtained prior to any construction and a Certificate of Occupancy must be obtained prior to occupancy. All plans must be prepared and stamped by a licensed Architect or Professional Engineer as per SDCL 36-18A. All erosion and sediment control devices must be installed prior to issuance of a Certificate of Occupancy.

Zoning: All provisions of the General Commercial District must be met unless otherwise specifically authorized as a stipulation of this Initial and Final Planned Commercial Development or a subsequent Major Amendment. The Initial and Final Planned Commercial Development will allow for car sales. Any change in use that is a permitted use in the General Commercial District will require the review and approval of a Minimal Amendment. Any change in use that is a Conditional Use in the General Commercial District will require the review and approval of a Major Amendment to the Planned Commercial Development.

Notification Requirement: As of this writing, the white slips and green cards from the certified mailing have not been returned and the required sign has not been posted on the property. Staff will notify the Planning Commission at the March 22, 2012 Planning Commission meeting if these requirements have not been met.