

No. PW072903-04

Building Inspection Division of Rapid City
Engineering Division
Dave La France

July 22, 2003

Request no side walk for building site at 913 West Street.

A side walk would not be consistent with the building site, as there are not any side walks on this side of the street, in this block. The elevation to walk on South Street is approximately 15 to 20 feet elevated above this lot and the lots to the north, are a steep hill to the curb between South Street and Columbus Street. There is an existing side walk on the east side of West Street.

Thank You
Richard O. Stahl

