

**REQUEST FOR EXCEPTION TO  
RAPID CITY DESIGN STANDARD / CRITERIA / REGULATIONS**

PROJECT Dewald

DATE: 7/11/08 SUBMITTED BY: Hodcock Const. Inc.

PIN #: 361 220 0001

LEGAL DESCRIPTION: see Attached

EXCEPTION REQUESTED: SECTION 5.2.4 STD / CRITERIA / REG Select One

DESCRIPTION OF REQUEST: Length of Cut-De-Sac exceeds the required 500 feet by 265 feet.

JUSTIFICATION: existing private drive,

SUPPORTING DOCUMENTATION:  Yes  No

PROPERTY OWNER'S SIGNATURE\*\*: [Signature] DATE: 7/11/08

\*\*Or Agent, if previously designated by the Owner in writing.

FOR STAFF ONLY

STAFF COMMENTS: No alternate emergency access.

STAFF RECOMMENDATION: Deny

REVIEWED BY: KMH DATE: 7/14/08

AUTHORIZATION:  APPROVED  DENIED  
Robert J. Dominick, DECC 7/14/08  
GROWTH MANAGEMENT DIRECTOR DATE

APPROVED  DENIED  
[Signature] 7/19/08  
PUBLIC WORKS DIRECTOR\* DATE

FILE #: 08EX071

ASSOCIATED FILE#: 08P1010, 08P1106

Revised 11/06/07

\*Public Works Director's signature is not required for Lot Length to Width Exceptions, Ordinance No. 5232