

turn around
veg

**REQUEST FOR EXCEPTION TO
RAPID CITY DESIGN STANDARD / CRITERIA / REGULATIONS**

PROJECT Dewald

DATE: 7/11/08 SUBMITTED BY: Hadcock Const. Inc.

PIN #: 3612200001

LEGAL DESCRIPTION: See Attached.

EXCEPTION REQUESTED: SECTION 5.2.3 STD / CRITERIA / REG Select One

DESCRIPTION OF REQUEST: Waive requirement for a turn around every 600 feet. Approx. 10 turn arounds needed. grade does not allow.

JUSTIFICATION: existing private drive

SUPPORTING DOCUMENTATION: Yes No

PROPERTY OWNER'S SIGNATURE**: [Signature] DATE: 7/11/08

**Or Agent, if previously designated by the Owner in writing.

FOR STAFF ONLY

STAFF COMMENTS: There will not be sufficient space for emergency vehicles to maneuver safely

STAFF RECOMMENDATION: Deny

REVIEWED BY: VMH DATE: 7/14/08

AUTHORIZATION: APPROVED DENIED
Robert R. Dominica, DSCC
GROWTH MANAGEMENT DIRECTOR DATE: 7/14/08

APPROVED DENIED
Stacy P. Miller
PUBLIC WORKS DIRECTOR* DATE: 7/14/08

FILE #: 08EX072

ASSOCIATED FILE#: 08PL000, 08PL100

Revised 11/06/07

*Public Works Director's signature is not required for Lot Length to Width Exceptions, Ordinance No 5232.