



NOTE

1. ALL FENCE WOOD SHALL BE #1 CEDAR
2. ALL HARDWARE SHALL BE GALVANIZED OR NON-CORROSIVE
3. FACEBOARDS SHALL BE SCREWED TO CROSSBOARDS. ALL CROSSBOARDS WILL BE SCREWED TO POSTS (1 3/4" SCREWS). ALL CONCRETE FOOTINGS SHALL BE 61 BAC MAX. 2500 PSI CONCRETE

FENCE CLEAR SEALANT NOTE:

1. CONTRACTOR TO USE OLYMPIC WOOD PROTECTOR CLEAR WATER-PROOFING SEALER OR CONSTRUCTION MANAGER APPROVED EQUAL OLYMPIC PRODUCT. MAY BE PURCHASED AT LOCAL HARDWARE STORE
2. CONTRACTOR SHALL APPLY 2" TW COATS OF ABOVE REFERENCE SEALER TO FENCE

ASSOCIATED ENGINEERING, INC.  
211 N. MAIN STREET  
CHANDLER, AZ 85226  
P. 480.947.8000  
F. 480.947.8000  
AZ REG. PROJECT # 44

REGISTERED PROFESSIONAL ENGINEER  
REG. NO. 6498  
TOM MEDHI  
AZ REG. PROJECT # 44

PROJECT MANAGER  
i wireless

APPLICATION NUMBER  
SWS, LLC

DRAWN BY: [blank] DATE: [blank]  
DATE: [blank] TIME: [blank]  
SITE NAME  
ST. ISAAC

WIRELESS SITE NUMBER  
SD0144

DRAWING TITLE  
FENCE DETAILS  
DRAWING NUMBER  
C-5  
JOB NUMBER