



RECEIVED

NOV 26 2013

MAYOR'S OFFICE

DEPARTMENT of ENVIRONMENT and NATURAL RESOURCES

JOE FOSS BUILDING
PMB 2020
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.denr.sd.gov

November 22, 2013

Sam Kooiker
City of Rapid City
300 6th St.
Rapid City, SD 57701-2724

EFFLUENT VIOLATION
WARNING LETTER



RE: Surface Water Discharge Permit SD0023574

Dear Mayor Kooiker:

The South Dakota Department of Environment and Natural Resources has recently completed a review of discharge monitoring results for compliance with your Surface Water Discharge permit limits for the City of Rapid City.

The purpose of this letter is to provide you with written documentation of effluent violations that were recently reported on your Discharge Monitoring Reports (DMRs). This letter does not take into account whether or not you notified the department as required in your permit.

The following are reported violations from submitted DMRs, not covered by another warning letter:

<u>DMR</u>	<u>Mth/Year</u>	<u>Parameter</u>	<u>Limit</u>	<u>Reported Value</u>
001A	7/ 2013	Coliform, fecal general	400 #/100mL DAILY MX	440 #/100mL

Your facility MUST make every effort to comply with ALL of your permit conditions. Violations can lead to an enforcement action which can include fines up to \$10,000 per day per violation.

If you feel you have received this letter in error, please contact me at (605) 773-4731.

Regards,

Tim Flor
Environmental Scientist III/Enforcement
Surface Water Quality Program

C: SWQ/Enforcement File