

**CITY OF RAPID CITY
CONSTRUCTION CHANGE ORDER**

PROJECT NAME: WRF UV Disinfection System and Post Aeration System Improvements

PROJECT NO: 14-2157

CONTRACTOR: PKG Contracting, Inc.




ORIGINAL CONTRACT AMOUNT: **\$2,276,900.00**

CHANGE ORDER NO.: 1

DATE: March 16, 2015

LINE ITEM	SEC NO	DESCRIPTION	UNIT	CONTRACT QUANTITY	UNIT PRICE	EXTENDED PRICE	INSTALLED QUANTITY	INSTALLED PRICE	INCREASE/(DECREASE)
1		Relocate Aeration Blowers Indoors	1	LS	\$10,498.00	\$10,498.00			\$10,498.00
2		Install Outdoor Inlet Air System for Aeration Blowers	1	LS	\$9,661.00	\$9,661.00			\$9,661.00
3		Supply 60 inch Sluice Gate for Effluent Bypass Pipe	1	LS	\$2,240.00	\$2,240.00			\$2,240.00
		Total							\$22,399.00

C.C.O. HISTORY INCREASE/(DECREASE)	PRIOR ADJUSTED CONTRACT PRICE :	\$2,276,900.00	
	NET INCREASE/(DECREASE):	\$22,399.00	
	ADJUSTED CONTRACT PRICE:	\$2,299,299.00	
PRIOR TOTAL	\$0.00	CHANGE TO DATE:	\$22,399.00

 CONTRACTOR: PKG CONTRACTING, INC.	2-24-15 DATE
 PROJECT MANAGER: DAN COON	2-27-15 DATE
 CITY ENGINEER: DALE TECH	3-2-15 DATE
MAYOR: SAM KOOIKER	DATE
FINANCE: PAULINE SUMPTION	DATE
CONTRACT TIME CHANGE 0 DAYS	NEW CONTRACT TIME:

City Staff recommends approval of this Change Order No. 1 with PKG Contracting, Inc. for an increase in Contract Price of \$22,399.00.

Initial Funding	\$2,276,900.00
Fund Type	Water Reclamation
Department	0833
Line Item	4380
Fund	0604
CCO #1	\$22,399.00
Adjusted Funding	\$2,299,299.00

**CITY OF RAPID CITY
CONSTRUCTION CHANGE ORDER**

PROJECT NAME: WRF UV Disinfection System and Post Aeration System Improvements

PROJECT NO. 14-2157

CONTRACTOR: PKG Contracting, Inc.

ORIGINAL CONTRACT AMOUNT: \$2,276,900.00

CHANGE ORDER NO.: 1

DATE: March 16, 2015

LINE ITEM	DESCRIPTION	REASON FOR CHANGE
1	Relocate Aeration Blowers Indoors	Move aeration blowers indoors to provide better protection of the equipment, reduce potential noise impact on neighborhood and provide for better work environment for maintenance procedures on the blowers.
2	Install Outdoor Inlet Air System for Aeration Blowers	Drawing the aeration inlet air from outside the building will provide for more efficient heating and cooling of the room in which the blowers are located and will prevent freezing of other equipment located in the blower room.
3	Supply 60 inch Sluice Gate for Effluent Bypass Pipe	Provide 60 inch sluice gate instead of 48 inch sluice gate for the effluent bypass pipe which will allow the gate to be attached to a more secure part of the support wall.

PREPARED BY: DAN COON

DATE: 2/27/2015