



CITY OF RAPID CITY

RAPID CITY, SOUTH DAKOTA 57701-2724

Growth Management Department

300 Sixth Street


Bob Dominical, Project Manager
Growth Management Department
city web: www.rcgov.org

Phone: 605-394-4120
Fax: 605-394-6636
e-mail: bob.dominicak@rcgov.org

MEMORANDUM

TO: Public Works Committee

CC: Marcia Elkins

FROM: Bob Dominicak, Project Manager 

DATE: March 16, 2005

RE: Exception to Drainage Criteria Manual

Centerline, on behalf of Lazy P-6 Land Company, Inc., has requested an exception to Section 9.3.4 Principal Outlet Works, of the Drainage Criteria Manual. This Section requires reinforced concrete pipe for the principal outlet pipes. Lazy P-6 Land Company, Inc. is requesting approval to substitute corrugated metal pipe for the reinforced concrete pipe. Section 1.2.4 of the Manual provides for exceptions to the Manual.

Lazy P-6's request is based on the premise that this outlet structure and outlet pipe are to be a temporary structure and will be reconstructed at the time Elm Street is constructed in this area. It is the opinion of staff that this section of Elm Street will be constructed within 5-10 years, therefore can accept the claim of this being a temporary structure. At the time of Elm Street construction the pipe and structure will be reconstructed as per City of Rapid City specifications and Drainage Criteria Manual.

Based on discussions with Centerline and Lazy P-6, this staff engineer concurs with and approves of this exception.



EQUAL OPPORTUNITY EMPLOYER