

STAFF REPORT
October 4, 2007

No. 07SR047 - SDCL 11-6-19 Review to construct a public electric utility substation. ITEM 42

GENERAL INFORMATION:

APPLICANT/ AGENT	Jim Pahl for West River Electric Assn.
PROPERTY OWNER	West River Electric Assn.
REQUEST	No. 07SR047 - SDCL 11-6-19 Review to construct a public electric utility substation.
EXISTING LEGAL DESCRIPTION	Lot WR of the NE1/4 NE1/4, Section 15 T1N, R8E, BHM, Pennington County, South Dakota
PARCEL ACREAGE	Approximately 1.333 acres
LOCATION	3383 Reservoir Road
EXISTING ZONING	Limited Agriculture District (Pennington County)
SURROUNDING ZONING	
North:	Planned Unit Development (Pennington County)
South:	Limited Agriculture District (Pennington County)
East:	Suburban Residential District (Pennington County)
West:	Limited Agriculture District (Pennington County)
PUBLIC UTILITIES	Rapid Valley Sanitation Service
DATE OF APPLICATION	8/24/2007
REVIEWED BY	Jonathan Smith / Todd Peckosh

RECOMMENDATION:

Staff recommends that the SDCL 11-6-19 Review to construct a public electric utility substation be denied.

GENERAL COMMENTS:

(Update September 25, 2007. All revised text is shown in bold). On September 17, 2007 the applicant submitted an updated, scaled site plan of the property. The site plan identifies a security chain link fence surrounding the property, property lines, structures, surface material, as well as proposed and existing approaches.

Staff has noted that a Vacation of a Non-Access Easement request (#07VE028) to vacate a 105 foot Non-Access Easement along Reservoir Road has been filed in conjunction with this SDCL 11-6-19 request. The plat document identifies the property as Lot WR of Paul Subdivision (#05PL237). Lot WR abuts Reservoir Road, which is classified by the Street Design Criteria Manual as a minor arterial street. The applicant's site plan

STAFF REPORT
October 4, 2007

No. 07SR047 - SDCL 11-6-19 Review to construct a public electric utility substation. ITEM 42

currently identifies two approach locations that do not meet the minimum spacing requirements of 150 feet. The 150 foot spacing between approaches applies for an approach along a minor arterial street in which traffic can access from both direction and has a speed limit of 35 miles per hour.

Staff has noted these approach locations do not meet the minimum spacing requirement and that vehicular circulation within the site could be improved by altering the locations of the proposed electric substations on the site. For this reason staff recommends that the SDCL 11-6-19 request to construct a public electric utility substation be denied.

The applicant has submitted a SDCL 11-6-19 Review to construct a public electric utility substation. The property is located at the southwest intersection of Longview Road and Reservoir Road. Currently an existing electric substation is located on the southern portion of the property. The northern portion of the property is being used for storage of electrical equipment. The applicant plans to construct another electric substation on the northern portion of the property. The property is not located within the municipal boundaries of the City of Rapid City; however, the property is located within the City of Rapid City's Three Mile Platting Jurisdiction. The property is currently zoned Limited Agriculture District by Pennington County.

South Dakota Codified Law 11-6-19 states: Whenever any such municipal council shall have adopted the comprehensive plan of the municipality or any part thereof, then and thenceforth, no street, park, or other public way, ground, place, space, no public building or structure, no public utility, whether publicly or privately owned, if covered by the comprehensive plan or any adopted part thereof, shall be constructed or authorized in the municipality or within its subdivision jurisdiction as defined in § 11- 6-26, until and unless the location and extent thereof shall have been submitted to and approved by the Planning Commission.

STAFF REVIEW:

Staff has reviewed the South Dakota Codified Law 11-6-19 Review and noted the following considerations:

SITE PLAN:

Staff has noted that the site plan submitted by the applicant is not sufficient for a thorough review. Staff recommends that prior to Planning Commission approval the applicant submit for review and approval a scaled site plan which identifies property lines, easements, structures, fences, landscaping, surface material, driveways, proposed and existing approaches, as well as existing and proposed contours.

FLOODPLAIN:

Staff has noted that the property is not located within the 100 year federally designated flood plain boundary.

SURFACE MATERIAL:

The applicant has submitted documentation stating that the surface material beneath and surrounding the proposed electric utility substation shall be gravel spread three to six inches in depth. The applicant has indicated that the protective gravel surface material can greatly

STAFF REPORT
September 20, 2007

No. «Filenumber» - «Action»

ITEM

reduce the shock current at the substation.