




409 Deadwood Avenue, PO Box 1400, Rapid City, SD 57709

(605) 721-3200

Black Hills Power is required by the National Electric Safety Code - NESC (110.A.1.b) to install at a minimum a 7Ft tall fence. BHP uses a standard of 7Ft of chain linked fabric, with an additional 1Ft of barbed wire. BHP requests required variances to the current requirements based on the NESC requirements as well as the standards used by Black Hills Power.



RECEIVED

APR 23 2009

Rapid City Growth
Management Department